



Certificate number: 2204712 (1)

Issued 08/04/2022

Expires 16/03/2027

Kiwa Regulation 4 (KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 – Regulation 4(1)(a)

Model number(s) – see Appendix

Flamco Limited.

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory
Kiwa Watertec

Publication of this certificate is allowed.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en/about-kiwa/water-products/> to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec
(A Trading Division of Kiwa Ltd)
26A Rassau Industrial Estate
Ebbw Vale
Gwent
NP23 5SD
United Kingdom
T +44 (0)1495 308185
uk.water@kiwa.com
www.kiwa.co.uk

Certificate Issued to:

Flamco Limited
Washway Lane
St Helens
Merseyside
WA10 6PB



Product Certificate

Appendix to Certificate number: 2204712

The following products belong to this certificate

PRODUCT DESCRIPTION Range of pressure reducing valves with DZR brass bodies. Adjustable between 1 and 6 bar. ATS3 – Without Production Surveillance.
MODEL(S) 27463 - 1 ¼" BSP (M) Union; 27464 - 1 ½" BSP (M) Union; 27465 - 2" BSP (M) Union;
SIZE: See model.
SCOPE: Manufacturer recommended maximum working pressure 25 Bar & maximum operating temperature 85°C. Hygienic Purposes: Non-metallic materials suitable for continuous use up to 85°C. Above ground use only.
MARKING Flamco logo, size, DN, flow arrow, DR and date of manufacturer (MM.YY on body).
MATERIALS Non-metallic materials assessed (BS6920) to point of discharge.
BACKFLOW PROTECTION NOTES N/A.
ADDITIONAL NOTES All water contact & exposed components satisfy opacity requirements.

Extra Notes