

**Manufacturer****Flamco BV**

Fort Blauwkapel 1, 1358 DB Almere, the Netherlands

Product description**Safety valves****Product type**

Prescor ½", ¾", 1", 1¼"	Set pressure: <i>Einstelldruck:</i>	1,0 - 5,0 bar
Prescor Solar ½", ¾", 1"	Set pressure: <i>Einstelldruck:</i>	3,0 - 10,0 bar
Prescomano ½", ¾"	Set pressure: <i>Einstelldruck:</i>	2,5 - 3,0 bar
Prescor B ½", ¾", 1"	Set pressure: <i>Einstelldruck:</i>	6,0 - 10,0 bar

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The object of the declaration described above is in conformity with the relevant legislation:

Pressure Equipment Regulation 2016, UK Statutory Instrument 2016 No. 1105, as amended by the Product Safety and Metrology etc. (Amendment etc.), (EU Exit) Regulations 2019, UK Statutory Instrument 2019 No. 696 2014

The conformity of the product described above with the provisions of the applied regulation(s) is demonstrated by compliance with the following Standards / regulations:

EN 12516-3:2002

Applied conformity assessment procedure	
Conformity Assessment Modules followed for Category I, II, III, IV	B + D
Data about safety valve, serial no., type and working limits	according to label
Medium	Water
Fluid group according to article 13	2
Certificate No. Module D, Quality assurance of the production process	0038/UKCA/PER/D/RQA664420
Certificate No. Module B, UKCA-Type examination –production type	0038/UKCA/PER/B/ROT/8037503
Conformity Assessment Body	Lloyd's Register Verification Ltd. 17 Fenchurch Street, London EC3M 4BS, U.K.
Marking Identification number on body	CE 0038

Almere, 02.08.2021

Signed for and on behalf of:

FLAMCO BV



M. van de Veen
Managing director