



Flextronic priručnik za povezivanje



- HVR **Priručnik za povezivanje**
Upute za ugradnju i rukovanje
- Flamconnect pristupnik
- Analogni izlazi
- Digitalni (diskretni) izlazi
- Sučelje za sustav za upravljanje zgradama (BMS)

Sadržaj

1. Ispravna upotreba	2
2. Opis proizvoda	2
2.1 Pojedinosti ožičenja	3
2.2 Flamconnect pristupnik	3
2.3 BMS Povezivost Modbus i BACnet	4
2.4 Međusobno povezani Flamco automati.....	4
2.5 Analogni izlazni signali (korisnik)	4
2.6 Digitalni (diskretni) izlazni signali.....	5
3. Bežična konfiguracija i postavke.....	5
3.1 Postavke komunikacijskog sučelja.....	6
3.2 Programiranje digitalnih (diskretnih) izlaza	6
4. Modbus tablica za mapiranje.....	7
4.1 Flamcomat.....	7
4.2 FlexFiller	9
5. BACnet tablica za mapiranje.....	12
5.1 Flamcomat.....	12
5.2 FlexFiller	14

Ovaj dokument je namijenjen kao dodatak uputama za ugradnju i rukovanje proizvodom.
Ova uputa posebno podržava Flamcomat G4, u smislu sigurnosti, uporabe i rada.

Upute za instalaciju i dodatna dokumentacija dostupni na različitim jezicima na stranici www.flamcogroup.com/manuals. Daljnje informacije o proizvodnji mogu se zatražiti od odgovarajuće podružnice tvrtke Flamco.

Legenda:

- | | |
|---|----------------------|
|  | Početna stranica |
|  | Postavke |
|  | Općenito |
|  | Servisne informacije |

1. Ispravna upotreba

Upravljačka jedinica Flextronic mora se koristiti u skladu s ovim priručnikom. Izjava o sukladnosti u izvornoj dokumentaciji i dalje vrijedi.

2. Opis proizvoda

Flextronic je univerzalna upravljačka jedinica za Flamco automate.

Ima širok raspon komunikacijskih mogućnosti koje se mogu aktivirati u izborniku Flextronic pribora:

1. Ethernet priključak za BMS integraciju, komunicirajući u protokolu Modbus ili BACnet.
2. USB priključak za spremanje operativnog dnevnika ili za ažuriranje firmvera.
3. Canbus veze (uparene za lančano povezivanje) za međusobno povezivanje više Flamco automata.
4. RS-485 veze (uparene za lančano povezivanje) za vezu Flamco Remote Service Gateway (Flamconnect) ili alternativno za BMS integraciju putem Modbusa ili BACneta.
5. Bežično sučelje (2 400...2 485 GHz) za uparivanje s pametnim telefonom ili tabletom.
6. Analogni izlazni signali napona za daljinsku indikaciju razine posude i tlaka u sustavu (0–10 V).
7. Digitalni (diskretni) izlazi (250 VAC, 5 A maks., bez potencijala). Uobičajene greške i upozorenja mogu se konfigurirati na tri porta u izborniku Flextronic Alarms.

Neoznačeni priključci namijenjeni su za određene dodatke automata ili za druge operativne svrhe. Ne smiju se koristiti za korisničko sučelje ili komunikaciju.


2.1 Pojedinosti ožičenja




Instalaciju, obradu podataka i puštanje u pogon mora izvoditi obučeno, kvalificirano i kompetentno osoblje. Odgovarajući nacionalni standardi, propisi i pravila moraju se poštivati. Upute za instalaciju i dodatna dokumentacija dostupni na različitim jezicima na stranici www.flamcogroup.com/manuals.

- Tvrta Flamco ne prilaže niti isporučuje dodatne kabele.
- Flamco preporučuje uporabu upletenog zaštićenog jednostrukog kabela.
- Završni otpor ima vrijednost 120 omu.
- Najveća dopuštena duljina kabela je 500 m.

2.2 Flamconnect pristupnik



2.3 BMS Povezivost Modbus i BACnet




Na RS-485 BUS nije moguća istovremena komunikacija Modbusa i BACneta. Ako su potrebna oba protokola, jedan od protokola mora se izvoditi preko Ethernet veze (IP).

Kada koristite Flamconnect Remote Service Gateway, RS485 priključnik namijenjen je za ovu značajku.


Ako je također potreban Modbus ili BACnet onda se to može postići samo pomoću Ethernet veze (IP).

2.4 Međusobno povezani Flextronic automati






2.5 Analogni izlazni signali (korisnik)

Za dobivanje naponskog analognog signala tlaka u sustavu i razine posude.



2.6 Digitalni (diskretni) izlazni signali



Za dobivanje statusa automata. Uobičajena pogreška može se dodijeliti svakom izlazu.

Izlaz P29 je signal za blokadu kotla u načinu rada $>110^{\circ}\text{C}$, u ovom načinu rada nije dostupan za alarmiranje.

3. Bežična konfiguracija i postavke

Konfiguracija je moguća pomoću aplikacije Flamconnect.

Za uparivanje: unesite šifru. Može se pronaći na naljepnici QR-koda na automatu ili će se prikazati na zaslonu.



	Informacije o sustavu	Za pregled informacija o automatu i upravljačkom uređaju	
---	-----------------------	--	---

Konfiguracija korisničkog sučelja i komunikacijskih protokola dostupna je u upravljačkom izborniku.

	Dodaci	Za aktivaciju naprednih automatskih dodataka	
---	--------	--	---

3.1 Postavke komunikacijskog sučelja

Ethernet:

IP adresa 192.168.100.150
IP maska 255.255.255.0
IP pristupnik 192.168.100.1

RS-485:

Flextronic je podčinjen.
ID uređaja odabirljiv
Brzina prijenosa 19 200
Paritet 8-n-1

Istom sučelju moguće je istovremeno dodijeliti samo jedan protokol. Kad je povezan Remote Service Gateway, Modbus i BACnet nisu dostupni preko RS-485. Umjesto toga koristite Ethernet priključak za BMS integraciju.



3.2 Programiranje digitalnih (diskretnih) izlaza

Postoji mogućnost da se uobičajena/e pogreška/e (greške i upozorenja) dodijele digitalnim (diskretnim) izlazima bez potencijala. Ako je istom izlazu dodijeljeno više pogrešaka, izlaz postaje aktivan ako je za taj izlaz aktivan bilo koji od dodijeljenih pogrešaka.

Konfiguriranje pogrešaka dostupno je u izborniku Flextronic:

	Alarmi	Za dodjelu alarmne dojave/a relevantnom/im izlazu/ima bez potencijala	
---	--------	---	---

4. Modbus tablica za mapiranje

4.1 Flamcomat

Register	Access	Name	Type	Unit	Range
0x0001	R	Current working pressure	UINT16	cbar	0..16000
0x0002	R	Current vessel level	UINT16	%	0...100
0x0003	R	Outputs state (1-on)	UINT16		Bit 0: P35 M1 Active (pump/compressor) Bit 1: P36 M2 Active (pump/compressor) Bit 2: P33 V1 active (Valve 1) Bit 3: P34 V2 active (Valve 2) Bit 4: P31 V3 Active (Valve 3/ Refill pump) Bit 8: Degassing On (Enabled)* Bit 9: Degassing mode (0-normal, 1-turbo)*
0x0004	R	Error table 1 (1-error active)	UINT16		Bit 0: Single pump/ compressor maximum run time error Bit 1: Redundant pumps/ compressor maximum run time error Bit 2: Load dependant pumps/ compressor maximum run time error Bit 3: Single pump/ compressor current error Bit 4: Pump A current error (double pump/ compressor configuration) Bit 5: Pump B current error (doublepump/ compressor configuration) Bit 6: Pumps A and B current error (double pump/ compressor configuration) Bit 7: Pump C/ compressor current error Bit 8: Self-learning valve correction error Bit 9: Self-learning pump correction error Bit 10: Pressure sensor current exceeded Bit 11: Pressure sensor no current Bit 12: Load cell current exceeded Bit 13: Load cell no current Bit 14: Pump A/ compressor power consumption too high Bit 15: Pump B/ compressor power consumption too high
0x0005	R	Error table 2 (1-error active)	UINT16		Bit 0: Pump C power consumption too high Bit 1: Maximum Runtime P35 M1 exceeded Bit 2: Maximum Runtime P36 M2 exceeded Bit 3: Maximum supplantation threaded water amount exceeded Bit 4: Pump running, no decrease of water level in vessel* Bit 5: Valve open, no increase of water level in vessel* Bit 6: Maximum runtime P33 V1 exceeded Bit 7: Maximum runtime P34 V2 exceeded Bit 8: To run quick fill* Bit 9: To run system fill* Bit 10: System run in auto mode Bit 11: Quick system filling active, V to stop* Bit 12: System filling active, V to stop* Bit 13: Manual mode active, press V to start automat Bit 14: Diaphragm rupture Bit 15: Spare
0x0006	R	Error table 3 (1-error active)	UINT16		Bit 0: Water level increase in vessel without Flamcomat activity* Bit 1: Water level decrease in vessel without Flamcomat activity* Bit 2: Maintenance 1 is due Bit 3: Initial fill failed Bit 4: Maximum refill time exceeded Bit 5: Maximum drain time exceeded* Bit 6: No refill flow Bit 7: Amount refill water too much Bit 8: Spare Bit 9: Spare Bit 10: Spare Bit 11: Initial fill active Bit 12: Manual initial fill active Bit 13: System fill timer expired Bit 14: Quick fill timer expired* Bit 15: Maintenance 2 is due

Register	Access	Name	Type	Unit	Range
0x0007	R	Error table 4 (1-error active)	UINT16		Bit 0: Maintenance 3 is due Bit 1: Maintenance 4 is due Bit 2: Spare Bit 3: Spare Bit 4: Spare Bit 5: Spare Bit 6: Spare Bit 7: Spare Bit 8: Spare Bit 9: Spare Bit 10: Spare Bit 11: Spare Bit 12: Spare Bit 13: Spare Bit 14: Spare Bit 15: Spare
0x0008	R	Operational hours total	UINT16	hours	
0x0009	R	Availability (0 - No, 1 - Yes)	UINT16		Bit 0: P35 M1 pressure increase Bit 1: P36 M2 Pressure increase Bit 2: P33 V1 (pressure decrease/ compressor valve) Bit 3: P34 V2 (pressure decrease/ compressor valve) Bit 4: P31 V3 (filling pump/valve) Bit 8: Minimum pressure limiter Bit 9: Diaphragm rupture sensor Bit 10: Maximum temperature sensor
0x000A	R	Pressure setpoint	UINT16	cbar	0..16000
0x000B	R	Minimum water level (absolute)	UINT16	%	
0x000C	R	Level refeeding On (absolute)	UINT16	%	
0x000D	R	Level refeeding Off (absolute)	UINT16	%	
0x000E	R	Minimum level alarm limit	UINT16	%	
0x000F	R	Maximum level alarm limit	UINT16	%	
0x0010	R	Nominal volume of vessel	UINT16	l	
0x0011	R	Operational mode	UINT16		0 - single mode, 1 - redundant mode 2 - load-dependent
0x0012	R	Total refill liters	UINT16	l	
0x0013	R	Total refill minutes	UINT16	minute	

* Not applicable for the Flamcomat MK-U G4

4.2 FlexFiller

Register	Access	Name	Type	Unit	Formatting
0x0000	R	SystemPressure	U16	mbar	Decimal
0x0001	R	SupplyPressure	U16	mbar	Decimal
0x0002	R	TankLevel	U16	%	Decimal
0x0003	R	VacuumPressure	U16	mbar	Decimal
0x000A	R	PressureSetpoint	U16	mbar	Decimal
0x000B	R	SafetyValveSetting	U16	mbar	Decimal
0x000C	R	Calculated_LowPressureAlarm	U16	mbar	Decimal
0x000D	R	Calculated_HighPressureAlarm	U16	mbar	Decimal
0x000E	R	VesselVolume	U16	l	Decimal
0x0030	R	DigitalInput	U16	Binary	NA
0x0031	R	DigitalOutput	U16	Binary	Bit 0: P36 (Pump 2 / NC) Bit 1: P35 (Pump 1 / Direct drain valve) Bit 2: P34 (NC) Bit 3: P33 (NC) Bit 4: P32 (NC) Bit 5: P31 (Refill / Inlet valve) Bit 6: P29 (VFC 1) Bit 7: P28 (VFC 2) Bit 8: P27 (VFC 3)
0x0032	R	AccessoryPresenceMask	U16	Binary	NA
0x0033	R	AccessoryPresenceMask	U16	Binary	NA
0x0034	R	DaysToTheNextMaintenance1	U16	count	Decimal
0x0035	R	DaysToTheNextMaintenance2	U16	count	Decimal
0x0036	R	DaysToTheNextMaintenance3	U16	count	Decimal
0x0037	R	DaysToTheNextMaintenance4	U16	count	Decimal
0x0040	R	Errors_3	U16	Binary	NA (For Future Use)
0x0041	R	Errors_2	U16	Binary	NA (For Future Use)
0x0042	R	Errors_1	U16	Binary	NA (For Future Use)
0x0043	R	Errors_0	U16	Binary	Bit 0: ALR_SYSTEM_PRESSURE_LOW Bit 1: ALR_SYSTEM_PRESSURE_BELOW_MINIMUM Bit 2: ALR_SYSTEM_PRESSURE_SENSOR_OOB_LOW Bit 3: ALR_SYSTEM_PRESSURE_SENSOR_OOB_HIGH Bit 4: ALR_SYSTEM_PRESSURE_HIGH Bit 5: ALR_SYSTEM_FILL_TIMER_EXPIRED Bit 6: ALR_SAFETY_VALVE_ACTIVE Bit 7: ALR_VESSEL_PRECHARGE_LOST Bit 8: ALR_PUMP_1_OVER_CURRENT Bit 9: ALR_PUMP_2_OVER_CURRENT Bit 10: ALR_PUMP_1_NO_CURRENT Bit 11: ALR_PUMP_2_NO_CURRENT
0x0044	R	Warnings_0	U16	Binary	NA (For Future Use)
0x0045	R	Warnings_1	U16	Binary	Bit 0: WRN_SYPHON_FLUSH_DETECTED

0x0046	R	Warnings_2	U16	Binary	Bit 0: WRN_SYSTEM_FILL_ACTIVE Bit 1: WRN_SYSTEM_FILL_ON_HOLD Bit 2: WRN_ANTI_LEGIONELLA_RUNNING Bit 3: WRN_DEVICE_REBOOT Bit 4: WRN_TANK_LEVEL_SENSOR_OOB_LOW Bit 5: WRN_TANK_LEVEL_SENSOR_OOB_HIGH Bit 6: WRN_PUMP_DRY_RUN Bit 7: WRN_TANK_OVERFLOW Bit 8: WRN_MANUAL_SYSTEM_FILL Bit 9: WRN_PUMP_1_RUNTIME Bit 10: WRN_PUMP_2_RUNTIME Bit 11: WRN_ANTI_LEGIONELLA_RECOVERY Bit 12: WRN_VACUUM_PRESSURE_SENSOR_OOB_LOW Bit 13: WRN_VACUUM_PRESSURE_SENSOR_OOB_HIGH Bit 14: WRN_FILTER_FULL Bit 15: WRN_VACUUM_ERROR
0x0047	R	Warnings_3	U16	Binary	Bit 0: WRN_SYSTEM_PRESSURE_HIGH Bit 1: WRN_MAX_AMOUNT_TOPUP_WATER Bit 2: WRN_SYSTEM_PRESSURE_LOW Bit 3: WRN_NUMBER_OF_TOPUPS Bit 4: WRN_SUPPLY_PRESSURE_TOO_LOW Bit 5: WRN_SUPPLY_PRESSURE_TOO_HIGH Bit 6: WRN_SUPPLY_PRESSURE_SENSOR_OOB_LOW Bit 7: WRN_SUPPLY_PRESSURE_SENSOR_OOB_HIGH Bit 8: WRN_SYSTEM_FILL_SELF_LEARNING Bit 9: WRN_MANUAL_MODE Bit 10: WRN_MAXIMUM_TOPUP_TIME_EXCEEDED Bit 11: WRN_NO_TOPUP_FLOW Bit 12: WRN_MAINTENANCE_1_DUE Bit 13: WRN_MAINTENANCE_2_DUE Bit 14: WRN_MAINTENANCE_3_DUE Bit 15: WRN_MAINTENANCE_4_DUE
0x0050	R	OverallRuntime_H	U16	h	Decimal (Combine 0x0050&0x0051 to read the full U32 value)
0x0051	R	OverallRuntime_L	U16	h	Decimal (Combine 0x0050&0x0051 to read the full U32 value)
0x0052	R	TotalFilledVolume_H	U16	ml	Decimal (Combine 0x0052&0x0053 to read the full U32 value)
0x0053	R	TotalFilledVolume_L	U16	ml	Decimal (Combine 0x0052&0x0053 to read the full U32 value)
0x0054	R	TotalFillTime_H	U16	s	Decimal (Combine 0x0054&0x0055 to read the full U32 value)
0x0055	R	TotalFillTime_L	U16	s	Decimal (Combine 0x0054&0x0055 to read the full U32 value)
0x0056	R	ActivationsMv1_H	U16	count	Decimal (Combine 0x0056&0x0057 to read the full U32 value)
0x0057	R	ActivationsMv1_L	U16	count	Decimal (Combine 0x0056&0x0057 to read the full U32 value)
0x0058	R	ActivationsMv2_H	U16	count	Decimal (Combine 0x0058&0x0059 to read the full U32 value)
0x0059	R	ActivationsMv2_L	U16	count	Decimal (Combine 0x0058&0x0059 to read the full U32 value)
0x005A	R	RuntimeMv1_H	U16	s	Decimal (Combine 0x005A&0x005B to read the full U32 value)
0x005B	R	RuntimeMv1_L	U16	s	Decimal (Combine 0x005A&0x005B to read the full U32 value)
0x005C	R	RuntimeMv2_H	U16	s	Decimal (Combine 0x005C&0x005D to read the full U32 value)
0x005D	R	RuntimeMv2_L	U16	s	Decimal (Combine 0x005C&0x005D to read the full U32 value)
0x005E	R	ActivationsPump1_H	U16	count	Decimal (Combine 0x005E&0x005F to read the full U32 value)
0x005F	R	ActivationsPump1_L	U16	count	Decimal (Combine 0x005E&0x005F to read the full U32 value)
0x0060	R	ActivationsPump2_H	U16	count	Decimal (Combine 0x0060&0x0061 to read the full U32 value)
0x0061	R	ActivationsPump2_L	U16	count	Decimal (Combine 0x0060&0x0061 to read the full U32 value)
0x0062	R	ActivationsValve1_H	U16	count	Decimal (Combine 0x0062&0x0063 to read the full U32 value)
0x0063	R	ActivationsValve1_L	U16	count	Decimal (Combine 0x0062&0x0063 to read the full U32 value)
0x0064	R	RuntimePump1_H	U16	s	Decimal (Combine 0x0064&0x0065 to read the full U32 value)
0x0065	R	RuntimePump1_L	U16	s	Decimal (Combine 0x0064&0x0065 to read the full U32 value)

0x0066	R	RuntimePump2_H	U16	s	Decimal (Combine 0x0066&0x0067 to read the full U32 value)
0x0067	R	RuntimePump2_L	U16	s	Decimal (Combine 0x0066&0x0067 to read the full U32 value)
0x0068	R	RuntimeValve1_H	U16	s	Decimal (Combine 0x0068&0x0069 to read the full U32 value)
0x0069	R	RuntimeValve1_L	U16	s	Decimal (Combine 0x0068&0x0069 to read the full U32 value)
0x006A	R	NrOfNormalTopUps_H	U16	count	Decimal (Combine 0x006A&0x006B to read the full U32 value)
0x006B	R	NrOfNormalTopUps_L	U16	count	Decimal (Combine 0x006A&0x006B to read the full U32 value)
0x006C	R	NrOfEmergencyStops_H	U16	count	Decimal (Combine 0x006C&0x006D to read the full U32 value)
0x006D	R	NrOfEmergencyStops_L	U16	count	Decimal (Combine 0x006C&0x006D to read the full U32 value)
0x006E	R	SafetyValveActivations_H	U16	count	Decimal (Combine 0x006E&0x006F to read the full U32 value)
0x006F	R	SafetyValveActivations_L	U16	count	Decimal (Combine 0x006E&0x006F to read the full U32 value)
0x0070	R	ActivationsVfc1_H	U16	count	Decimal (Combine 0x0070&0x0071 to read the full U32 value)
0x0071	R	ActivationsVfc1_L	U16	count	Decimal (Combine 0x0070&0x0071 to read the full U32 value)
0x0072	R	ActivationsVfc2_H	U16	count	Decimal (Combine 0x0072&0x0073 to read the full U32 value)
0x0073	R	ActivationsVfc2_L	U16	count	Decimal (Combine 0x0072&0x0073 to read the full U32 value)
0x0074	R	ActivationsVfc3_H	U16	count	Decimal (Combine 0x0074&0x0075 to read the full U32 value)
0x0075	R	ActivationsVfc3_L	U16	count	Decimal (Combine 0x0074&0x0075 to read the full U32 value)

5. BACnet tablica za mapiranje

5.1 Flamcomat

Object identifier	Access	Object Name	Type	Unit	Range
OBJECT_ANALOG_VALUE:0	R	Current working pressure	UINT16	cbar	0..16000
OBJECT_ANALOG_VALUE:1	R	Current vessel level	UINT16	%	0...100
OBJECT_ANALOG_VALUE:2	R	Outputs state (1-on)	UINT16		Bit 0: P35 M1 active (pump/ compressor) Bit 1: P36 M2 active (pump/ compressor) Bit 2: P33 V1 active (valve 1) Bit 3: P34 V2 active (valve 2) Bit 4: P31 V3 active (valve 3) Bit 8: Degassing On (Enabled)* Bit 9: Degassing mode (0-normal, 1-turbo)*
OBJECT_ANALOG_VALUE:3	R	Error table 1 (1-error active)	UINT16		Bit 0: Single pump/ compressor maximum run time error Bit 1: Redundant pumps/ compressor maximum run time error Bit 2: Load dependent pumps/ compressor maximum run time error Bit 3: Single pump/compressor current error Bit 4: Pump A current error (double pump/ compressor configuration) Bit 5: Pump B current error (double pump/ compressor configuration) Bit 6: Pumps A and B/ compressor current error (double pump c configuration) Bit 7: Pump C/ compressor current error Bit 8: Self-learning valve correction error Bit 9: Self-learning pump/ compressor correction error Bit 10: Pressure sensor current exceeded Bit 11: Pressure sensor no current Bit 12: Load cell current exceeded Bit 13: Load cell no current Bit 14: Pump A/ compressor power consumption too high Bit 15: Pump B/ compressor power consumption too high
OBJECT_ANALOG_VALUE:4	R	Error table 2 (1-error active)	UINT16		Bit 0: Pump C/ compressor power consumption too high Bit 1: Maximum runtime P35 M1 exceeded Bit 2: Maximum runtime P36 M2 exceeded Bit 3: Maximum supplantation threaded water amount exceeded Bit 4: Pump/ compressor running, no decrease of water level in vessel Bit 5: Valve open, no increase of water level in vessel Bit 6: Maximum runtime P33 V1 exceeded Bit 7: Maximum runtime P34 V2 exceeded Bit 8: To run quick fill* Bit 9: To run system fill* Bit 10: System run in auto mode Bit 11: Quick system filling active, V to stop* Bit 12: System filling active, V to stop* Bit 13: Manual mode active, press V to start automat Bit 14: Diaphragm rupture Bit 15: Spare

Object identifier	Access	Object Name	Type	Unit	Range
OBJECT_ANALOG_VALUE:5	R	Error table 3 (1-error active)	UINT16		Bit 0: Water level increase in vessel without Flamcomat activity* Bit 1: Water level decrease in vessel without Flamcomat activity* Bit 2: Maintenance 1 is due Bit 3: Initial fill failed Bit 4: Maximum refill time exceeded Bit 5: Maximum drain time exceeded* Bit 6: No refill flow Bit 7: Amount refill water too much Bit 8: Spare Bit 9: Spare Bit 10: Spare Bit 11: Initial fill active Bit 12: Manual initial fill active Bit 13: System fill timer expired* Bit 14: Quick fill timer expired* Bit 15: Maintenance 2 is due
OBJECT_ANALOG_VALUE:6	R	Error table 4 (1-error active)	UINT16		Bit 0: Maintenance 3 is due Bit 1: Maintenance 4 is due Bit 2: Spare Bit 3: Spare Bit 4: Spare Bit 5: Spare Bit 6: Spare Bit 7: Spare Bit 8: Spare Bit 9: Spare Bit 10: Spare Bit 11: Spare Bit 12: Spare Bit 13: Spare Bit 14: Spare Bit 15: Spare
OBJECT_ANALOG_VALUE:7	R	Operational hours total	UINT16	hours	
OBJECT_ANALOG_VALUE:8	R	Availability (0 - No, 1 - Yes)	UINT16		Bit 0: P35 M1 pressure increase Bit 1: P36 M2 Pressure increase Bit 2: P33 V1 (pressure decrease/ compressor valve) Bit 3: P34 V2 (pressure decrease/ compressor valve) Bit 4: P31 V3 (filling pump/ valve) Bit 8: Minimum pressure limiter Bit 9: Diaphragm rupture sensor Bit 10: Maximum temperature sensor
OBJECT_ANALOG_VALUE:9	R	Pressure setpoint	UINT16	cbar	0..16000
OBJECT_ANALOG_VALUE:10	R	Minimum water level (absolute)	UINT16	%	
OBJECT_ANALOG_VALUE:11	R	Level refeeding On (absolute)	UINT16	%	
OBJECT_ANALOG_VALUE:12	R	Level refeeding Off (absolute)	UINT16	%	
OBJECT_ANALOG_VALUE:13	R	Minimum level alarm limit	UINT16	%	
OBJECT_ANALOG_VALUE:14	R	Maximum level alarm limit	UINT16	%	
OBJECT_ANALOG_VALUE:15	R	Nominal volume of vessel	UINT16	l	
OBJECT_ANALOG_VALUE:16	R	Operational mode	UINT16		0 - single mode, 1 - redundant mode 2 - load-dependent
OBJECT_ANALOG_VALUE:17	R	Total refill liters	UINT16	l	
OBJECT_ANALOG_VALUE:18	R	Total refill minutes	UINT16	minute	

* Not applicable for the Flamcomat MK-U G4

5.2 FlexFiller

Object ID	Access	Object name	Type	Unit	Formatting
OBJECT_ANALOG_VALUE:0	R	"alarms"	U64	Binary	Bit 0: ALR_SYSTEM_PRESSURE_LOW Bit 1: ALR_SYSTEM_PRESSURE_BELOW_MINIMUM Bit 2: ALR_SYSTEM_PRESSURE_BELOW_MINIMUM Bit 3: ALR_SYSTEM_PRESSURE_SENSOR_OOB_HIGH Bit 4: ALR_SYSTEM_PRESSURE_HIGH Bit 5: ALR_SYSTEM_FILL_TIMER_EXPIRED Bit 6: ALR_SAFETY_VALVE_ACTIVE Bit 7: ALR_VESSEL_PRECHARGE_LOST Bit 8: ALR_PUMP_1_OVER_CURRENT Bit 9: ALR_PUMP_2_OVER_CURRENT Bit 10: ALR_PUMP_1_NO_CURRENT Bit 11: ALR_PUMP_2_NO_CURRENT
OBJECT_ANALOG_VALUE:1	R	"warnings"	U64	Binary	Bit 0: WRN_SYSTEM_PRESSURE_HIGH Bit 1: WRN_MAX_AMOUNT_TOPUP_WATER Bit 2: WRN_SYSTEM_PRESSURE_LOW Bit 3: WRN_NUMBER_OF_TOPUPS Bit 4: WRN_SUPPLY_PRESSURE_TOO_LOW Bit 5: WRN_SUPPLY_PRESSURE_TOO_HIGH Bit 6: WRN_SUPPLY_PRESSURE_SENSOR_OOB_LOW Bit 7: WRN_SUPPLY_PRESSURE_SENSOR_OOB_HIGH Bit 8: WRN_SYSTEM_FILL_SELF_LEARNING Bit 9: WRN_MANUAL_MODE Bit 10: WRN_MAXIMUM_TOPUP_TIME_EXCEEDED Bit 11: WRN_NO_TOPUP_FLOW Bit 12: WRN_MAINTENANCE_1_DUE Bit 13: WRN_MAINTENANCE_2_DUE Bit 14: WRN_MAINTENANCE_3_DUE Bit 15: WRN_MAINTENANCE_4_DUE Bit 16: WRN_SYSTEM_FILL_ACTIVE Bit 17: WRN_SYSTEM_FILL_ON_HOLD Bit 18: WRN_ANTI_LEGIONELLA_RUNNING Bit 19: WRN_DEVICE_REBOOT Bit 20: WRN_TANK_LEVEL_SENSOR_OOB_LOW Bit 21: WRN_TANK_LEVEL_SENSOR_OOB_HIGH Bit 22: WRN_PUMP_DRY_RUN Bit 23: WRN_TANK_OVERFLOW Bit 24: WRN_MANUAL_SYSTEM_FILL Bit 25: WRN_PUMP_1_RUNTIME Bit 26: WRN_PUMP_2_RUNTIME Bit 27: WRN_ANTI_LEGIONELLA_RECOVERY Bit 28: WRN_VACUUM_PRESSURE_SENSOR_OOB_LOW Bit 29: WRN_VACUUM_PRESSURE_SENSOR_OOB_HIGH Bit 30: WRN_FILTER_FULL Bit 31: WRN_VACUUM_ERROR Bit 32: WRN_SYPHON_FLUSH_DETECTED
OBJECT_ANALOG_VALUE:2	R	"current system pressure"	U16	mbar	Decimal
OBJECT_ANALOG_VALUE:3	R	"current supply pressure"	U16	mbar	Decimal
OBJECT_ANALOG_VALUE:4	R	"current tank level"	U16	%	Decimal
OBJECT_ANALOG_VALUE:5	R	"current vacuum pressure"	U16	mbar	Decimal
OBJECT_ANALOG_VALUE:6	R	"pressure setpoint"	U16	mbar	Decimal
OBJECT_ANALOG_VALUE:7	R	"safety valve setting"	U16	mbar	Decimal
OBJECT_ANALOG_VALUE:8	R	"low pressure alarm limit"	U16	mbar	Decimal
OBJECT_ANALOG_VALUE:9	R	"high pressure alarm limit"	U16	mbar	Decimal
OBJECT_ANALOG_VALUE:10	R	"vessel volume"	U16	l	Decimal

OBJECT_ANALOG_VALUE:11	R	"digital input"	U16	Binary	NA
OBJECT_ANALOG_VALUE:12	R	"digital output"	U16	Binary	Bit 0: P36 (Pump 2 / NC) Bit 1: P35 (Pump 1/MV1 topup valve) Bit 2: P34 (NC) Bit 3: P33 (NC) Bit 4: P32 (NC) Bit 5: P31 (Inlet valve/MV2 Drain Valve) Bit 6: P29 (VFC 1) Bit 7: P28 (VFC 2) Bit 8: P27 (VFC 3)
OBJECT_ANALOG_VALUE:13	R	"accessories"	U32	Binary	NA
OBJECT_ANALOG_VALUE:14	R	"days to next maintenance 1"	U16	count	Decimal
OBJECT_ANALOG_VALUE:15	R	"days to next maintenance 2"	U16	count	Decimal
OBJECT_ANALOG_VALUE:16	R	"days to next maintenance 3"	U16	count	Decimal
OBJECT_ANALOG_VALUE:17	R	"days to next maintenance 4"	U16	count	Decimal
OBJECT_ANALOG_VALUE:18	R	"overall runtime"	U32	h	Decimal
OBJECT_ANALOG_VALUE:19	R	"total filled volume"	U32	ml	Decimal
OBJECT_ANALOG_VALUE:20	R	"total fill time"	U32	s	Decimal
OBJECT_ANALOG_VALUE:21	R	"activations MV1"	U32	count	Decimal
OBJECT_ANALOG_VALUE:22	R	"activations MV2"	U32	count	Decimal
OBJECT_ANALOG_VALUE:23	R	"runtime MV1"	U32	s	Decimal
OBJECT_ANALOG_VALUE:24	R	"runtime MV2"	U32	s	Decimal
OBJECT_ANALOG_VALUE:25	R	"activations Pump1"	U32	count	Decimal
OBJECT_ANALOG_VALUE:26	R	"activations Pump2"	U32	count	Decimal
OBJECT_ANALOG_VALUE:27	R	"activations Valve1"	U32	count	Decimal
OBJECT_ANALOG_VALUE:28	R	"runtime Pump1"	U32	s	Decimal
OBJECT_ANALOG_VALUE:29	R	"runtime Pump2"	U32	s	Decimal
OBJECT_ANALOG_VALUE:30	R	"runtime Valve1"	U32	s	Decimal
OBJECT_ANALOG_VALUE:31	R	"nrOfNormalTopUps"	U32	count	Decimal
OBJECT_ANALOG_VALUE:32	R	"nrOfEmergencyStops"	U32	count	Decimal
OBJECT_ANALOG_VALUE:33	R	"safetyValveActivations"	U32	count	Decimal
OBJECT_ANALOG_VALUE:34	R	"activationsVfc1"	U32	count	Decimal
OBJECT_ANALOG_VALUE:35	R	"activationsVfc2"	U32	count	Decimal
OBJECT_ANALOG_VALUE:36	R	"activationsVfc3"	U32	count	Decimal

Kontakt

Nizozemska

hydronic flow control
+31 36 520 62 300
info@flamcogroup.com
www.flamcogroup.com

Belgija

hydronic flow control
+32 2 371 01 67
info@flamco.be

Kina

Flamco Heating Accessories
(Changshu) Ltd, Co.
+86 512 528 417 31
yecho@flamco.com.cn

Češka

Flamco CZ s.r.o.
+420 284 00 10 81
info@meibes.cz

Danska

Flamco Denmark
+45 44 94 02 07
info@flamco.dk

Estonija

Flamco Baltic
+372 568 838 38
info@flamco.ee

Finska

Flamco Finland
+358 10 320 99 90
info@flamco.fi

Francuska

hydronic flow control
+33 4 78 78 16 00
info@flamco.fr

Njemačka

Meibes System-Technik GmbH
+49 342 927 130
info@meibes.com

Njemačka

Flamco GmbH
+49 2104 80006 20
info@flamco.de

Mađarska

Flamco Kft
+36 23 880981
info@flamco.hu

Italija

Flamco Italy
+39 030 258 6005
flamco-italia@flamcogroup.com

Poljska

Flamco Meibes Sp. z o.o.
+48 65 529 49 89
info@flamco.pl

Rusija

ООО „Майбес РУС“
+7 495 727 20 26
moscow@flamcogroup.ru

Slovačka

Flamco SK s.r.o.
+421 475 634 043
info@meibes.sk

Švedska

Flamco Sverige
+46 50 042 89 95
vvs@flamco.se

Švicarska

Flamco AG
+41 41 854 30 50
info@flamco.ch

Ujedinjeni Arapski Emirati

Flamco Middle East
+971 4 8819540
info@flamco-gulf.com

Ujedinjeno Kraljevstvo

Flamco Limited
+44 17 447 447 44
info@flamco.co.uk

Flamco B.V.
Fort Blauwkapel 1
1358 DB Almere
the Netherlands
+31 36 52 62 300
info@flamcogroup.com
www.flamcogroup.com

Autorska prava Flamco B.V., Almere, Nizozemska. Nijedan dio ove publikacije ne smije se reproducirati ili objaviti na bilo koji način bez izričitog dopuštenja i spominjanja izvora. Navedeni podaci primjenjivi su isključivo na Flamco proizvode. Flamco B.V. ne prihvata nikakvu odgovornost za nepravilnu uporabu, primjenu ili tumačenje tehničkih podataka. Flamco B.V. zadržava pravo na tehničke promjene.